

# TEST CERTIFICATE

Issued to: BMT Co., Ltd..  
21-1, Bukjeong-dong Yangsan-si  
Gyeongsangnam-do  
KOREA

For the product: Low voltage switchgear and controlgear assembly

Trade name: BMT

Type/Model: 400 A – MDB

Ratings: lcw 30 kA - 1 s (3P), 18 kA – 1 s (Neutral and PE)  
lcw 21,2 kA - 2 s (3P), 12,7 kA – 2 s (Neutral and PE)

Manufactured by: BMT Co., Ltd..  
21-1, Bukjeong-dong Yangsan-si  
Gyeongsangnam-do  
KOREA

Subject: Short circuit withstand verification, protection against electric shock and integrity of protective circuits

Requirements: IEC 61439-2:2011  
Clauses 10.5.2, 10.5.3, 10.11

Remarks: -

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2158235.01-INC, dated 21 December 2012.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 21 December 2012

Number: 2158235.100

DEKRA Certification B.V.

H.R.M. Barends  
Certification Manager



© Integral publication of this certificate and adjoining reports is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands  
T +31 26 356 2000 F +31 26 352 5800 [www.dekra-certification.com](http://www.dekra-certification.com) Company registration 09085396